


**PRELIMINARY ENGINEERING REPORT**  
FOR:

**TOWN OF EDISTO BEACH, SC**  
**WATER SYSTEM IMPROVEMENTS**

**PREPARED FOR:**  
**TOWN OF EDISTO BEACH, SC**

**J – 25683.0000**

**FEBRUARY, 2017**



Prepared by:



**THOMAS & HUTTON**

[www.thomasandhutton.com](http://www.thomasandhutton.com)

## TABLE OF CONTENTS

1. Introduction.....	Page 1
2. General Information .....	Page 1
3. Service Area & Existing Water System.....	Page 2
4. Proposed Project.....	Page 5
5. Water Demand.....	Page 7
6. Supply & Transmission Line.....	Page 7
7. Treatment .....	Page 10
8. Storage.....	Page 15
9. Control System.....	Page 15
10. Hydraulic Model.....	Page 19
11. Summary.....	Page 21

### FIGURES:

Location Map .....	3.1
Water System Map.....	3.2
Water System Improvements Map .....	4.1
Proposed Well Diagram .....	6.1
RO Treatment Plant-Floor Plan.....	7.1
RO Treatment Plant-Elevation Section .....	7.2
RO Treatment Plant & Well #7 Site Plan.....	7.3
Process & Instrumentation Diagrams.....	9.1
Process Flow Diagram .....	9.2
Hydraulic Modeling Graph – Option 4C.....	10.1

**TABLES**

Summary of Existing Potable Supply Wells.....3.1

Total Average Well Production.....5.1

Proposed Potable Supply Wells.....6.1

Summary of RO Plant Flow Rates .....7.1

Water Quality Projections .....7.2

**CHARTS**

Edisto Beach-2015 Water Use .....9.2

**APPENDICES:**

Lab Analysis – Existing Well #6 ..... Appendix A

Reverse Osmosis System Analysis .....Appendix B

**1. INTRODUCTION**

The existing water system is in full compliance with primary regulations but is non-compliant with current Fluoride secondary standards. Also, because the water system has other significant issues with taste and corrosiveness, the Town of Edisto Beach has voted to proceed with major improvements to the water system which will correct any deficiencies and quality concerns currently identified. This Preliminary Engineering Report (PER) will describe specific water system improvements proposed to meet these goals set by Town Council:

- A. Improve water quality.
- B. Increase ability of the system to meet peak daily demand (PDD).
- C. Design for projected demand of 20% above current average daily demand (ADD).
- D. Utilize existing system components to the fullest extent possible.

**2. GENERAL INFORMATION**

- A. DHEC System ID Number: 15WS002
- B. DHEC Operating Permit Number: SC1510006
- C. Responsible Official, Town of Edisto Beach, SC  
Name & Title: Jane Darby, Mayor  
  
Address: 2414 Murray Street  
Edisto Beach, SC 29438  
  
Phone: (843) 869-2505
- D. Director of Public Works, Town of Edisto Beach, SC  
Name & Title: Bob Doub, Class "C" Treatment License, Class "A" Distribution  
  
Address: 2414 Murray Street  
Edisto Beach, SC 29438  
  
Phone: (843) 869-2505
- E. Engineer  
Name: Thomas & Hutton Engineering Co.  
  
Address: 682 Johnnie Dodds Blvd., Suite 100  
Mt. Pleasant, SC 29464  
  
Phone: (843) 849-0200  
  
Engineer: Mark F. Yodice, P.E., No. SC 13293

**3. SERVICE AREA & EXISTING WATER SYSTEM**

The Town of Edisto Beach is located at the end of Hwy. 174 approximately 20 miles south of Hwy. 17 as shown on **Figure 3.1**. Edisto Beach consists of the island bounded by the Atlantic Ocean, Edisto River and Big Bay Creek as shown on **Figure 3.2**. The Edisto Beach water system service area includes the area within the Town limits and it also serves the Edisto State Park and businesses along Hwy. 174 up to Palmetto Rd. including the True Value Hardware Store shopping complex located near this intersection. All areas north of Palmetto Rd. are located in Charleston County and are therefore not served. A large portion of the economy is based upon tourism. The terrain is flat and soils are sandy with a high groundwater table, especially at high tide.


There are currently 641 permanent residents but there are 2,360 water customers due to the resort nature of this community. Most customers are single family residential with a mixture of condominiums and commercial. A large portion of the residential units are rentals for visitors especially during the summer months. There are 2185 residential customers (92.6%) and 175 commercial customers (7.4%). Meters are read on a 6-month basis to coincide with the billing cycle.

**Figure 3.2** indicates the location of components that comprise the existing public water supply including; six active wells, 100,000-gallon elevated storage tank (ET), 200,000-gallon ground storage tank (GST) with booster pumps and a water distribution system. Four of the six active wells pump directly into the distribution system after being treated with only chlorination (sodium hypochlorite). The two remaining wells are located off-island in Edisto State Park and they pump directly into the 200,000-gallon GST after receiving chlorination and they are controlled by water level in the GST. The two boosters deliver water from the GST to the distribution system at an average pumping rate of 500 gpm, and they are driven with VFD motors. The boosters are controlled by water level in the elevated tank. A summary of the existing well characteristics is presented in Table 3.1.

<b>TABLE 3.1</b> <b>Town of Edisto Beach</b> <b>Summary of Existing Potable Supply Wells</b>						
Well No.	Location	Depth (feet)		Casing Size (inches)	Year Completed	Capacity (gpm)
		Bore Hole	Casing			
#1	Dockside	555	539	8	1979	250
#2	Bay Point	552	346	6	1962	135
#3	Lions Club	565	540	4	1975	90
#4	Edisto Park	562	534	6	1973	186
#5	Edisto Park	593	532	8	1993	276
#6	McConkey	580	540	8	2000	495

URS RO/ASR Feasibility Study 2012

**Figure 3.1**  
**Location Map**



# EDISTO BEACH RO WTP

## LOCATION MAP

CLIENT:

**TOWN OF EDISTO BEACH**

LOCATION: COLLETON COUNTY, SOUTH CAROLINA

DATE: 12-1-16

DRAWN BY: DNF

SHEET: FIG. 3.1

JOB NUMBER: J-25683.0001

REVIEWED BY: LRC

SCALE: NO SCALE



### THOMAS & HUTTON

Engineering | Surveying | Planning | GIS | Consulting

682 Johnnie Dodds Blvd. • Suite 100  
Mt. Pleasant, SC 29464 • 843.849.0200

[www.thomasandhutton.com](http://www.thomasandhutton.com)

**Figure 3.2**


**Water System Map**




Z:\25683\25683.0001\Engineering\Drawings\Exhibits\Fig 3.2.dwg - Feb 7, 2017 - 10:40:32 AM

**LEGEND**

- EXISTING 6" WATER LINE
- EXISTING 8" WATER LINE
- EXISTING 10" WATER LINE
- EXISTING WELL
- EXISTING TANK



**NOTE:**  
EXISTING WATER LINES BELOW 6" ARE NOT SHOWN FOR CLARITY.



**TOWN OF EDISTO BEACH**

Figure 3.2 - Water System Map

CLIENT:  
TOWN OF EDISTO BEACH

LOCATION: COLLETON COUNTY, SC

DATE: 10/04/16      DRAWN BY: DNF      SHEET: FIGURE 3.2

JOB NUMBER: 25683.0001      REVIEWED BY: LRC      SCALE: 1" = 1200'

**THOMAS & HUTTON**  
Engineering | Surveying | Planning | GIS | Consulting

682 Johnnie Dodds Blvd. • Suite 100  
Mt. Pleasant, SC 29464 • 843.849.0200

www.thomasandhutton.com

#### **4. PROPOSED PROJECT**

The Town developed an intensive program for the selection of a Progressive Design/Build team to complete the water system's improvements. The team selected for this project includes:

- Wharton-Smith, Inc., Sanford, FL, General Contractor
- Harn RO Systems, Inc., Venice, FL, RO Equipment Manufacturer
- Thomas & Hutton, Mt. Pleasant, SC, Design/Permitting Engineer

The team developed eight various options with associated costs and presented this to the Town in a matrix format during Phase 1 of the project. The options consisted of combinations including; Middendorf or Santee well supply, aquifer storage and recovery (ASR) or clearwell storage, various sizes of reverse osmosis (RO) treatment plants, two different locations for the RO plant and concentrate discharge lines, use of existing GST during peak demand season. The team provided budget pricing and prepared a hydraulic model for each option to compare their ability to meet PDD with fire flow. The Town selected Option 4C consisting of the improvements as shown on **Figure 4.1** and more fully described in the following sections.

Phase 1 of this Progressive Design/Build also includes completion of this PER and sufficient design detail to allow the team to present a Guaranteed Maximum Price (GMP) for the complete project to the Town. Phase 2 will not begin until the Town accepts the GMP and authorizes the team to proceed and it will consist of completion of construction drawings, procurement of required permits, construction, and commissioning of the project.

**Figure 4.1**  
**Water System Improvements Map**



J:\2016\25683.000\Engineering\Drawings\DWG\4.1 - Proposed Improvements.dwg Jan 8, 2017 4:46:57 PM





FIG. 4.1

**WATER SYSTEM IMPROVEMENTS MAP**  
 COLLETON COUNTY, SC  
 PREPARED FOR:  
**TOWN OF EDISTO BEACH**  
 PREPARED BY:

**THOMAS & HUTTON**  
Engineering | Surveying | Planning | GIS | Consulting

682 Johnnie Dodds Blvd. • Suite 100  
 Mt. Pleasant, SC 29464 • 843.849.0200  
 www.thomasandhutton.com

JOB NO: J-25683.0001	DATE: 10/13/16
DRAWN: DNF	SCALE: 1" = 300'
REVIEWED: LRC	SHEET: C1



## 5. WATER DEMAND

With direction from the Town, the team utilized previous engineering studies and historical water use records to develop the projected water demand for design purposes. Previous studies concluded that the average daily water demand per customer was 250 gallons per day (gpd). Current customer base is 2,350; therefore, current average daily demand (ADD) is 587,500 gpd. Table 5.1 is a table of well-pumping records over a 6-year period as reported to SCDHEC which indicates an average usage of 530,720 gpd over that period of time.

The current ADD of 587,500 gpd should be conservative since water usage has been declining over recent years and the service area is approximately 87% built out. The Town requested that projections for future demand should be limited to 20% more than current usage; therefore, the design ADD will be 705,000 gpd (587,500 gpd X 1.2).

<b>TABLE 5.1</b>						
<b>Town of Edisto Beach</b>						
<b>Total Average Well Production (gpd)</b>						
<b>Well #</b>	<b>2010</b>	<b>2011</b>	<b>2012</b>	<b>2013</b>	<b>2014</b>	<b>2015</b>
1	53,351	46,800	49,660	60,236	56,041	51,142
2	40,112	45,263	46,164	43,504	39,748	51,214
3	31,712	32,479	24,615	26,819	31,901	21,096
4	85,200	89,068	50,951	70,205	53,082	40,504
5	150,819	166,329	189,900	163,151	156,025	125,526
6	229,855	208,055	228,890	147,559	147,890	129,444
ADD (gpd)	<b>591,049</b>	<b>587,995</b>	<b>590,180</b>	<b>511,474</b>	<b>484,688</b>	<b>418,926</b>
Peak Day		1,410,300	1,263,800	1,095,600	1,244,300	
Peak Factor		<b>2.40</b>	<b>2.14</b>	<b>2.14</b>	<b>2.57</b>	

Well records also indicate that the peak daily demand (PDD) factor has ranged between 2.14 to 2.57. A peaking factor of 2.30 was chosen for design purposes which yields a PDD of 1,621,500 gpd (1.622 mgd) or 1,126 gpm.

## 6. SUPPLY & TRANSMISSION LINE

The goal of this project is to supply only water treated by the RO plant at all times so the supply wells will be piped directly to the RO plant. Total well capacity to the plant will be 1,521 gpm consisting of three existing wells and two new wells drilled into the Santee aquifer. Although it is not possible to predict the exact capacity of the proposed wells, each will be 10-inch diameter designed to accommodate a submersible pump and motor with a capacity of at least 507 gpm each.

The system must be carefully monitored to ensure that current groundwater withdrawal limits are not exceeded. Annual withdrawal permit currently allows 256 MG/year to be withdrawn from the aquifer or an average of 701,370 gpd. The proposed RO system will produce 553,713 gpd based upon this withdrawal limit. Assuming a 2% increase in water

use annually and the 2015 system usage average of 418,926 gpd, this withdrawal limit will be reached in the year 2029. A January 9, 2017 letter from DHEC recommends: "if increased usage indicates that the permitted withdrawal amount needs to be increased, the Department will gladly review a request for an increase at that time".

This first new well (Well #7) will be located on the site of the proposed RO plant as indicated on **Figure 7.3**. The location of the second new well is yet to be determined but it will most likely be located near the plant yet at a distance to minimize interference with the first well. The Town is currently negotiating for ownership of "Tract M" as shown on **Figure 4.1** and may select this site as the location of the second new well (Well #8). However, for purposes of this report it will be assumed that the second new well will be located at the site of existing Well #3 and will be labeled "New Well #3A" as indicated on **Figure 4.1**.

Existing wells #1, 2, and 6 will be connected to the RO plant with a dedicated transmission line as indicated on **Figure 4.1**. Chlorination of these wells will be discontinued since the RO plant will be designed to treat raw well water with post chemical addition including chlorination. All wells will have variable frequency drive (VFD) motors controlled by a new SCADA system. The remainder of the existing wells will be removed from the distribution system upon completion of the improvements, but will remain on standby status for emergency use only. Table 6.1 lists the existing and proposed wells that will provide the supply to the proposed RO Plant. Well #6 will be upgraded to 510 gpm.

All wells connected to the RO plant must be flushed to reduce the silt density index (SDI) for a period of time prior to discharging into the transmission line to the plant. An automatic valve will be installed on the discharge piping of each well. The valves will be controlled by SCADA based upon the flushing time required for each well. The flush water will be discharged into nearby drainage systems.

The new wells will be constructed as shown on the typical well diagram **Figure 6.1**. The wells will be completed with submersible pumps and motors with the well casing fitted with a blind flange to protect against the 100-year flood. VFD motors will allow the pumps to deliver 510-750 gpm. All piping extending through the well casing will be installed with welded fittings including the discharge piping, power cord conduit, airline conduit, and vent pipe. The vent pipe will be extended to an elevation of 1 foot above the 100-year flood elevation. All electrical switch gear and controls will be housed in pedestal-mounted NEMA 6X stainless steel panels. Each of the new wells will be designed and constructed in accordance with SCDHEC regulations unless waivers are granted.

<b>TABLE 6.1</b>						
<b>Town of Edisto Beach</b>						
<b>Proposed Potable Supply Wells</b>						
Well No.	Location	Depth (feet)		Casing Size (inches)	Year Completed	Capacity (gpm)
		Bore Hole	Casing			
#1	Dockside	555	539	8	1979	250
#2	Bay Point	552	346	6	1962	135
#6	McConkey	580	540	8	2000	495
#7	RO Plant	600	540	10	2017	510
#8	TBD	600	540	10	2017	510

**Figure 6.1**

**Proposed Well Diagram**



DEPTH, IN FEET BELOW LAND SURFACE (SEE NOTE 2)




FIGURE 6.1

**NOTES:**

1. NOT TO SCALE.
2. ACTUAL DEPTHS WILL BE DETERMINED LATER BY THE DRILLER AND ARE SHOWN FOR ILLUSTRATIVE PURPOSES ONLY.
3. DATUM = MSL.
4. FLANGED CAP SHALL BE TAPPED FOR PRESSURE GAUGE AND RAW WATER SAMPLE TAP.

**PROPOSED WELL DIAGRAM**

PROPOSED ACTIVITY:  
750 GPM DEEP WELL - OPEN HOLE CONSTRUCTION

CLIENT:  
TOWN OF EDISTO BEACH

LOCATION: EDISTO BEACH, SC  
DATE: 12/06/16 DRAWN BY: DNF SHEET: 1 OF 1  
JOB NUMBER: J-25683.0001 REVIEWED BY: KEN SCALE: N.T.S.

**THOMAS & HUTTON**  
Engineering | Surveying | Planning | GIS | Consulting

682 Johnnie Dodds Blvd. • Suite 100  
Mt. Pleasant, SC 29464 • 843.849.0200

www.thomasandhutton.com

## 7. TREATMENT

The proposed RO plant will be located on Town-owned property located on the south side of Murray St. (Lee St.) between Holmes and Loring Streets as shown on **Figure 4.1** with dimensions of 75 feet X 308 feet. The property is zoned PB which allows water treatment facilities. This site will not be adequate for future plant expansion; however, the Town feels plant capacity will be sufficient through buildout. The 100-year flood elevation at this location is 15 feet above MSL in a VE zone according to FEMA; however, the latest draft of the FEMA map indicates this location is in an AE zone with the 100-year flood elevation of 9 feet above MSL. Ground elevation at this location averages from 6 to 7 feet above MSL.

The operating floor of the treatment plant will be elevated to at least 2 feet above the 100-year flood elevation, as it will be supported by a reinforced concrete clearwell with an 11-foot water depth.

Treatment units will consist of three RO trains rated at 320 gpm permeate per train for a total permeate production 960 gpm. The system will be designed for 75% recovery and 20% raw water blend. Scale inhibitor will be added prior to the cartridge filters. The blended product water; therefore, will be 1,200 gpm total for all trains or a 24-hour production rate of 1.728 million gallons per day (mgd). The blended water will be further treated after the RO and blending processes by addition of calcium chloride for stabilization and sodium hypochlorite for disinfection before discharging into the clearwell. These chemicals will be housed in a separate room located within the treatment plant building. Three high service pumps (HSP) will deliver the finished water from the clearwell into the distribution system. The pumps will be located at the opposite end of the clearwell from the discharge point of the treated water. These pumps will be vertical turbine pumps with VFDs; one will be rated at 1,200 gpm while the other two will be rated at 600 gpm each. Concentrate from the RO process will be piped from the plant to the Atlantic Ocean along Loring Street as shown on **Figure 4.1**. Concentrate flow rate from each train will be 106.64 gpm for a total flow rate of 320 gpm when the plant is operating at full capacity. The concentrate line will be installed by horizontal directional drilling (HDD) under the dunes and ocean floor to the discharge point where a diffuser will be installed to properly mix the concentrate with ocean water. An NPDES Permit will be required for this discharge. **Table 7.1** is a summary of plant flow rates.

<b>TABLE 7.1</b>						
<b>Town of Edisto Beach</b>						
<b>Summary of RO Plant Flow Rates (gpm)</b>						
	Raw	Feed	Blend	Permeate	Finished	Concentrate
Skid #1	506.67	426.67	80.00	320.03	400.03	106.64
Skid #2	506.67	426.67	80.00	320.03	400.03	106.64
Skid #3	506.67	426.67	80.00	320.03	400.03	106.64
<b>Total</b>	<b>1520</b>	<b>1280</b>	<b>240</b>	<b>960</b>	<b>1200</b>	<b>320</b>

A 24-hour pump test was conducted on existing Well #6 during November 2016 and samples were collected for lab analysis. Lab analysis of the existing groundwater supply is included as **Appendix A**. High levels of chloride, sodium, bicarbonate alkalinity, and total dissolved solids were reported in this raw groundwater sample. All of these parameters are, of course, secondary standards, but to achieve the Town’s goal of improved water quality, the RO plant will be designed to reduce these to acceptable levels.

Harn R/O Systems, Inc. prepared a computer analysis to predict finished water quality based upon their specific design of an RO treatment system. The design includes a 20% blend of raw water with permeate from the RO units as requested by the Town. Town officials conducted a “taste test” of water from their existing RO dispensing station at Town Hall that was blended with well water from the distribution system in ratios of 10% and 20%. The 20% blend was selected by the Town which will provide more treatment capacity with the same treatment units and it will still meet Town water quality goals and will comply with primary and secondary water standards. The computer analysis of the selected RO system is included as **Appendix B** and a summary of the water quality is shown in Table 7.2 below:


<b>TABLE 7.2</b>			
<b>Town of Edisto Beach</b>			
<b>Water Quality Projections</b>			
<b>Parameter</b>	<b>Raw (mg/l)</b>	<b>Permeate (mg/l)</b>	<b>Blended (mg/l)</b>
Bicarbon. Alkalinity	519	25.75	126.06
Sodium	512	18.14	123.52
Chloride	490	12.8	108.24
Fluoride	2.56	0.12	0.61
pH	8.9	8.3	8.92
TDS	1680	64.64	396.71

*Raw water quality based upon testing from well #6 sample collected November 2015*

An emergency generator will be located on the same level as the treatment plant operations floor but outside the building. The generator will be sized to provide sufficient power for a minimum plant operating capacity of ½ PDD (480 gpm) during power outages. The generator fuel tank will be double-walled and self-contained located under the generator. The motor control center will be located in a separate room within the building. The plant building will also include a control room where the SCADA control system will be located and a separate room will contain the HSP system.

**Figure 7.1** is a conceptual layout of the operating floor while **Figure 7.2** shows an elevation view of the proposed treatment facility including the clearwell. **Figure 7.3** is a site plan of the proposed plant and proposed new well #7. The facility construction will comply with state and local codes and regulations.

**Figure 7.1**  
**RO Treatment Plant**  
**Floor Plan**



**A**  
**RO PLANT - UPPER LEVEL LAYOUT**  
 FIG. 7.1 1/4"=1'-0"


FIG. 7.1

UPPER LEVEL LAYOUT  
**EDISTO BEACH RO WTP**  
 COLLETON COUNTY, SOUTH CAROLINA  
 PREPARED FOR:  
**TOWN OF EDISTO BEACH**  
 PREPARED BY:  
**THOMAS & HUTTON**  
Engineering | Surveying | Planning | GIS | Consulting  
 682 Johnnie Dodds Blvd. • Suite 100  
 Mt. Pleasant, SC 29464 • 843.849.0200  
 www.thomasandhutton.com

JOB NO: J-25683.0002	DATE: 01-10-17
DRAWN: DNF	SCALE: AS SHOWN
REVIEWED: LRC	SHEET: FIG. 7.1

NOTE:  
 1. LOWER LEVEL TO BE MECHANICAL ROOM FOR ELEVATOR. UPPER LEVEL TO BE MECHANICAL SPACE FOR BLDG., HVAC, ETC.

**Figure 7.2**  
**RO Treatment Plant**  
**Elevation Section**



# EDISTO BEACH RO WTP

FIGURE 7.2  
BUILDING SECTION

CLIENT:  
TOWN OF EDISTO BEACH

LOCATION: COLLETON COUNTY, SOUTH CAROLINA  
DATE: 10-31-16  
JOB NUMBER: J-25683.0002

DRAWN BY: DNF  
REVIEWED BY: LRC

SHEET: C1  
SCALE: 1" = 5'



682 Johnnie Dodds Blvd. • Suite 100  
Mt. Pleasant, SC 29464 • 843.849.0200

[www.thomasandhutton.com](http://www.thomasandhutton.com)

**Figure 7.3**

**RO Treatment Plant & Well #7**

**Site Plan**








FIGURE 7.3

SITE PLAN

**EDISTO BEACH RO WTP**  
COLLETON COUNTY, SOUTH CAROLINA

PREPARED FOR:  
**TOWN OF EDISTO BEACH**

PREPARED BY:

**THOMAS & HUTTON**  
Engineering | Surveying | Planning | GIS | Consulting

682 Johnnie Dodds Blvd. • Suite 100  
Mt. Pleasant, SC 29464 • 843.849.0200  
www.thomasandhutton.com

<small>JOB NO: J-25483.0002</small>	<small>DATE: 11-8-16</small>
<small>DRAWN: DNF</small>	<small>SCALE: 1" = 20'</small>
<small>REVIEWED: MFY</small>	<small>SHEET: EX-1</small>

## 8. STORAGE

The clearwell, located under the treatment facility, discussed above, will cover an area of approximately 3,518 square feet (SF) and will contain 290,000 gallons at an 11-foot water depth. The clearwell is designed to provide in excess of the required 30-minute chlorine detention time and to allow for more continuous operation of the RO plant. The clearwell will be vented through the operations room floor (clearwell ceiling) and through the plant building wall to the exterior of the building. The top of the clearwell will be 2 feet above the 100-year flood elevation. Finished water in the clearwell will be discharged into the distribution system with the HSPs as previously described. A water level transducer within the clearwell will control the operation of the RO plant and supply wells.


The existing 200,000-gallon GST at Edisto State Park will be available for use during peak demand periods. As described previously, the GST will be used to store treated water only and the existing wells that now fill this tank will be taken offline. An automatic control valve (ACV) will be installed on a new line to be constructed between the GST and the existing 10-inch discharge line from the booster pumps that delivers water to the distribution system. The valve will open to fill the tank with treated water from the distribution system only during periods of lower demand during peak demand days (approximately 11:00 pm – 4:00 am). The ACV will be closed at all other times allowing the booster pumps to deliver stored water from the GST to the system upon demand.

The existing 100,000-gallon elevated storage tank will remain in service and the level in the tank will continue to provide the signal for the operation of water supply to the distribution system. Tank level now controls the operation of the wells but will control the operation of the HSP's after these improvements are completed. An ACV will be installed on the line feeding this tank. This ACV will close when the ACV at the GST is open and will reopen when the GST ACV closes.

## 9. CONTROL SYSTEM

A new supervisory control and data acquisition (SCADA) system will be installed to automatically control the operation of the water system. The existing system is now controlled by an antiquated proprietary SCADA system that requires replacement. The new SCADA system will receive data transmission from the remote locations through RF signals. The control center will be located in the control room at the water treatment facility. The Process & Instrumentation Diagram (P&ID) is included as **Figure 9.1**. This diagram graphically illustrates the control system for the improved water system. The P&ID specifically for the proposed RO system is also included as **Figure 9.1**. **Figure 9.2**, Process Flow Diagram, is a representation of the proposed improvements and existing infrastructure that will be included in the completed project and it depicts the flow of water through the various processes.

Basically, the level in the existing elevated tank will control the operation of the HSPs and the water level in the clearwell will control the operation of the water supply wells and, in turn, the operation of the RO plant. It is anticipated that there may be at least 3 different modes of operation depending upon seasonal demands. Since the improved water system is designed to meet PDD during the tourist season, treated water may become aged during the winter months unless operational changes are made. The SCADA system will allow those changes to be easily made on the touch-screen monitor. The 3-skid RO plant provides the flexibility to run only one skid during the winter months of low demand, 2 skids during average demand, or all 3 skids during peak demand months. The RO units should be run as continuously as possible and this arrangement will allow for the rotation of the skids on a daily basis during periods of lower demand increasing efficiency and allowing for maintenance of the idle skids. **Chart 9.2** shows actual system water use during 2015. The significant increase in water use during the summer months demonstrates the need for flexibility of the facility control system.



The GST may only be needed during periods of peak demand. The control system can be adjusted to allow the tank to fill during early morning hours of peak demand days and pump into the system during peak demand hours that same day as described previously.


**Figure 9.1**  
**Process & Instrumentation Diagram**




# Process and Instrumentation Diagram Legend

NOTE: ALL FITTINGS TO BE STANDARD DIMENSIONS UNLESS OTHERWISE NOTED.


## PROCESS DEVICE SYMBOLS



## INSTRUMENT LINE SYMBOLS



## GENERAL INSTRUMENT SYMBOLS



## IDENTIFICATION LETTERS

LETTER	FIRST LETTER		SUCCEEDING LETTERS		
	MEASURED OR INITIATING VARIABLE	MODIFIER	READOUT OR PASSIVE FUNCTION	OUTPUT FUNCTION	MODIFIER
A	ANALYSIS		ALARM		
B	BURNER, COMBUSTION		USER'S CHOICE	USER'S CHOICE	USER'S CHOICE
C	CONDUCTIVITY (ELECTRICAL)			CONTROL	
D	USER'D CHOICE	DIFFERENTIAL			
E	VOLTAGE (EMF)		PRIMARY ELEMENT		
F	FLOW RATE	RATIO (FRACTION)			
G	USER'S CHOICE		GLASS		
H	HAND (MANUALLY INITIATED)				HIGH
I	CURRENT (ELECTRICAL)		INDICATE		
J	POWER	SCAN			
K	TIME OR TIME-SCHEDULE	TIME RATE OF CHANGE		CONTROL STATION	
L	LEVEL		LIGHT (PILOT)		LOW
M	MOISTURE OR HUMIDITY	MOMENTARY			MIDDLE OR INTER-MEDIATE
N	USER'S CHOICE		USER'S CHOICE	USER'S CHOICE	USER'S CHOICE
O	USER'S CHOICE		ORIFICE (RESTRICTION)		
P	PRESSURE OR VACUUM		POINT (TEST CONNECTION)		
Q	QUANTITY	INTEGRATE OR TOTALIZE	INTEGRATE OR TOTALIZE		
R	RADIATION		RECORD OR PRINT		
S	SPEED OR FREQUENCY	SAFETY		SWITCH	
T	TEMPERATURE			TRANSMIT	
U	MULTIVARIABLE		MULTIFUNCTION	MULTIFUNCTION	MULTIFUNCTION
V	VIBRATION			VALVE, DAMPER, OR LOUVER	
W	WEIGHT OR FORCE		WELL		
X	UNCLASSIFIED		UNCLASSIFIED	UNCLASSIFIED	UNCLASSIFIED
Y	EVENT, STATE, OR PRESENCE			RELAY OR COMPUTE	
Z	POSITION, DIMENSION			DRIVE, ACTUATOR OR UNCLASSIFIED FINAL CONTROL ELEMENT	

## FUNCTION DESIGNATIONS

### INSTRUMENT MODIFIERS

- $\Sigma$  ADD OR SUM (ADD AND SUBTRACT)
- $\Delta$  SUBTRACT (DIFFERENCE)
- $\sqrt{\quad}$  EXTRACT SQUARE ROOT
- $\div$  DIVIDE
- $\int$  INTEGRATE (TIME INTEGRAL)
- Cl<sub>2</sub> CHLORINE
- CO<sub>2</sub> CARBON DIOXIDE
- COND CONDUCTIVITY
- DO DISSOLVED OXYGEN
- pH pH
- TURB TURBIDITY
- MCC MOTOR CONTROL CENTER

NOTE:  
1. THE P & ID SYMBOLS etc. ARE BASED ON THE INSTRUMENT SOCIETY OF AMERICA (ISA), STANDARD ANSI/ISA-S5.1 (1984).


### HAND SWITCH MODIFIERS

- HOA HAND OFF AUTO
- OAC OPEN AUTO CLOSE
- LR LOCAL REMOTE
- OC OPEN-CLOSE
- OO ON-OFF
- OOR ON-OFF-REMOTE
- OSC OPEN-STOP-CLOSE
- TBR TOP-BOTTOM-REMOTE

### TRANSDUCER & CONVERTER DESIGNATION

- E VOLTAGE
- FSK FREQUENCY SHIFT KEYING
- H HYDRAULIC
- I CURRENT
- P PNEUMATIC
- PD PULSE DURATION
- PF PULSE FREQUENCY
- R RESISTANCE (ELECTRICAL)

## VALVE AND ACTUATOR SYMBOLS




## PROPRIETARY INFORMATION!

This information is provided for the use of the Owner and the Engineer on this specific project – for bid evaluation and execution by Harn R/O Systems, Inc. The Owner and Engineer shall maintain the information in confidence. All proprietary information is the property of Harn R/O Systems, Inc. and shall be returned to Harn R/O Systems, Inc. or destroyed if the project is not executed by Harn R/O Systems, Inc.

## COMPUTER SYSTEMS INTERFACE SYMBOLS

NOTE: REFER TO DETAILED SYSTEM SPECIFICATIONS FOR FUNCTIONAL DESCRIPTION. ALSO SEE I/O SCHEDULES FOR COMPLETE INPUT AND OUTPUT LISTINGS.



**PRELIMINARY**

PRELIMINARY	BY:	DATE:	#	DESCRIPTIONS	DATE	DRN	REL
PROCESS DESIGN MANAGER			01	PRELIMINARY	09/30/16	DFS	
PROJECT ENGINEER							
SHOP SUPERVISOR							
CADD SUPERVISOR							



310 CENTER COURT  
VENICE, FL 34285  
(941)488-9671

JOB NO:	15-2100C
DATE:	09/30/16
DESIGN BY:	DFS
DRAWN BY:	DFS
SCALE:	NTS
CHECKED BY:	
APPROVED BY:	

JOB:	TOWN OF EDISTO BEACH
DRAWING TITLE:	WATER SYSTEM IMPROVEMENT PROJECT
Process and Instrumentation Diagram Legend	

DRAWING NO.	15-2100C-PID-00
SUB ASSEMBLY PAGE NO.	1 of 3
DRAWING SET PAGE NO.	




# R/O Process and Instrumentation Diagram

NOTE: ALL FITTINGS TO BE STANDARD DIMENSIONS UNLESS OTHERWISE NOTED.

## PROPRIETARY INFORMATION!

This information is provided for the use of the Owner and the Engineer on this specific project – for bid evaluation and execution by Harn R/O Systems, Inc. The Owner and Engineer shall maintain the information in confidence. All proprietary information is the property of Harn R/O Systems, Inc. and shall be returned to Harn R/O Systems, Inc. or destroyed if the project is not executed by Harn R/O Systems, Inc.

### LEGEND



TYPICAL OF TRAIN 1

### TAG LEGEND:

ASV - ANTI-SIPHON VALVE  
AV - AIR VENT  
BFV - BUTTERFLY VALVE  
BV - BALL VALVE  
CF - CARTRIDGE FILTER  
CV - CHECK VALVE  
DV - DIAPHRAGM VALVE  
FCV - FLOW CONTROL VALVE


### COMPONENT

MPV - MULTIPORT VALVE  
RD - RUPTURE DISK  
RDS - RUPTURE DISK SENSOR  
PI - PRESSURE INDICATOR  
PS - PRESSURE SWITCH  
TS - TEMPERATURE SWITCH

### PROCESS

0 - PRETREATMENT  
1 - R/O TRAIN 1  
2 - R/O TRAIN 2  
3 - BLEND  
4 - FINISHED WATER  
5 - CLEANING SYSTEM

XXX - ###  
COMPONENT NUMBER  
PROCESS  
COMPONENT



**PRELIMINARY  
REVISED**



PRELIMINARY  
PROCESS DESIGN MANAGER  
PROJECT ENGINEER  
SHOP SUPERVISOR  
CADD SUPERVISOR

BY:	DATE:	REVISIONS	#	DESCRIPTIONS	DATE	DRN	REL
		01		PRELIMINARY	09/30/16	DFS	
		02		PRELIMINARY-REVISED BLEND FLOW AND LINE SIZE AND WELL INLET FLOW AND PRE-TREAT FLOW	12/08/16	DFS	
		03		PRELIMINARY - REVISED PERMEATE AND CONCENTRATE FLOWS PER COMMENTS.	01/10/17	DFS	



310 CENTER COURT  
VENICE, FL 34285  
(941)488-9671

JOB NO: 15-2100C  
DATE: 09/30/16  
DESIGN BY: DFS  
DRAWN BY: DFS  
SCALE: NTS  
CHECKED BY:  
APPROVED BY:


JOB: TOWN OF EDISTO BEACH  
WATER SYSTEM IMPROVEMENT PROJECT  
DRAWING TITLE: R/O Process and Instrumentation Diagram

DRAWING NO. 15-2100C-PID-00  
SUB ASSEMBLY PAGE NO. 2 of 3  
DRAWING SET PAGE NO.

**Figure 9.2**  
**Process Flow Diagram**




2024081315483.0002 Engineering\Projects\Edisto Beach WTP\Fig. 9.2.dwg - 12/6/16



**OPERATING CONDITIONS**

NO. OF TRAINS ON	REQUIRED RAW WATER FLOW (gpm)	RO FEED FLOW (gpm)	BLENDED PRODUCT FLOW (gpm)	CONCENTRATE FLOW (gpm)
1	507	427	400	107
2	1014	854	800	214
3	1521	1281	1200	321



- NOTES:**
- PROPOSED WELLS #3A AND #7 WILL BE DESIGNED AS VFD WITH VARIABLE FLOW RATES 500-750 GPM. EACH WELL WILL NORMALLY SUPPLY 507 GPM TO FEED ONE RO SKID.
  - EXISTING WELLS #1, #2 & #6 WILL BE RETROFITTED WITH VFD'S. WELL #6 PUMPING RATE WILL BE INCREASED FROM 495 GPM TO 507 GPM.

**PUMP INFORMATION**

PUMP	LOCATION	CAPACITY (gpm)	TDH (ft)	H.P.	VOLTAGE	PHASE	SPEED
WELL #2	BAY POINT	135					VARIABLE
WELL #6	McCONKEY SITE	507					VARIABLE
WELL #1	DOCKSIDE	250					VARIABLE
WELL #3A (NEW)	LIONS CLUB	750	270	75	480	3	VARIABLE
WELL #7 (NEW)	RO WTP	750	270	75	480	3	VARIABLE
HSP1 (NEW)	ONSITE (HSP)	600	162	40	460	3	VARIABLE
HSP2 (NEW)	ONSITE (HSP)	600	162	40	460	3	VARIABLE
HSP3 (NEW)	ONSITE (HSP)	1200	162	75	460	3	VARIABLE
RO FEED 1	RO BUILDING	427	290	50	480	3	VARIABLE
RO FEED 2	RO BUILDING	427	290	50	480	3	VARIABLE
RO FEED 3	RO BUILDING	427	290	50	480	3	VARIABLE
CP #1	CLEANING PUMP	200	N/A	15	480	3	CONSTANT
ISB #1	INTERSTAGE BOOSTER	N/A	92	10	480	3	CONSTANT
ISB #2	INTERSTAGE BOOSTER	N/A	92	10	480	3	CONSTANT
ISB #3	INTERSTAGE BOOSTER	N/A	92	10	480	3	CONSTANT

- NOTES:**
- DESIGN DATA FOR NEW RO 1, 2 AND 3 PROVIDED BY HARN R/O SYSTEMS.

LINE NUMBER (WELL #)	(1A) 2	(1B) 6, 8, 1	(1C)	(1D) 3A	(1E)	(1F) 7	(1)	(2)	(3)	(4)	(4A)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(20)	(A)	(B)			
PARAMETER	RAW WELL WATER	RAW WELL WATER	RAW WELL WATER	RAW WELL WATER	RAW WELL WATER	RAW WELL WATER	COMBINED RAW WELL WTR	RO FEED WATER	CART. FILT. INLET	CART. FILT. OUTLET	RO FEED	RO PUMP SUCTION	RO PUMP DISCHARGE	RO UNIT PERMEATE	RO UNIT CONC.	COMBINED CONC.	COMBINED PERMEATE	NOT USED	COMBINED CONC.	WELL WATER FLUSH	BLENDED PRODUCT	NEW HSP DSCHG COMB.	BYPASS	SCALE INHIBITOR	POST CHEMICAL FEED			
FLOW, gpm	135	757	892	750	1642	750	2392	1521													321	1200	2400					
PRESSURE, psig									SEE HARN R/O SYSTEMS P & ID SHEETS																			
PIPE DIAMETER, inch	6	10	10	8	12	8	12	12													6	12	16					
PIPE MATERIAL	PVC C900	PVC C900	PVC C900	PVC C900	PVC C900	PVC C900	PVC C900	PVC S80													PVC C900	PVC C900	DIP					
FLUID VELOCITY, fps	1.5	3.1	3.6	4.8	4.7	4.8	6.8	4.3													3.6	3.6	3.8					
COMMENTS	EXISTING WELL NO. 2 (BAY POINT)	EXISTING WELL NO. 6 & NO. 1	MANHOLE PIPING FOR WELLS	NEW WELL NO. 3A (LIONS CLUB)	MANHOLE PIPING FOR WELLS	NEW PRODUCTION WELL NO. 7	COMBINED RAW WATER (RO FEED)	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW INSIDE BUILDING	NEW OUTSIDE DISCHARGE	NEW LINE	NEW LINE		

**FIG. 9.2**

**PROCESS FLOW DIAGRAM**

**EDISTO BEACH RO WTP**  
COLLETON COUNTY, SOUTH CAROLINA

PREPARED FOR:  
**TOWN OF EDISTO BEACH**

PREPARED BY:

**THOMAS & HUTTON**  
Engineering | Surveying | Planning | GIS | Consulting

682 Johnnie Dodds Blvd. • Suite 100  
Mt. Pleasant, SC 29464 • 843.849.0200

www.thomasandhutton.com

JOB NO: J-25483.0002	DATE: 12-6-16
DRAWN: DNF	SCALE: NOT TO SCALE
REVIEWED: LRC	SHEET: FIG. 9.2

## 10. HYDRAULIC MODEL

A computerized hydraulic model of the entire water system developed during previous engineering studies was updated for recent infrastructure improvements and current operating data. Data for proposed improvements was entered into the model for each of the 8 options considered during the matrix development process. This data included but was not limited to:


- Supply wells pressure and flow rates.
- RO plant treatment capacity.
- HSPs pressure and flow rates.
- Clearwell volume per foot of depth.
- Elevated storage tank volume per foot of depth and corresponding elevations.
- ASR pressure and flow rate.
- GST volume per foot of depth.
- GST booster pumps pressure and flow rates.
- PDD and fire flow within the water distribution system.

The model was manipulated with various control points for pumps, RO plant, ASR and tank elevations to provide sizing for each proposed improvement option required to meet PDD with a fire flow of 1,000 gpm for 2 hours impressed during PHD. PHD peaking factor of 2.1 X PDD was used to be conservative since AWWA average PHD factor is 1.8 X PDD. Many options failed to meet the required conditions and were eliminated from consideration. The options that did meet the required conditions were compared on an initial cost and a life cycle basis.

**Figure 10.1** is a graph of the model results for selected Option 4C. It shows tank levels and pumping rates for existing infrastructure and the new improvements included with this option during PDD with 1,000 gpm fire flow for 2 hours during the peak hour. Even though it is highly unlikely that this scenario will ever occur, the modeling results indicate that Option 4C will be capable of meeting this demand provided all infrastructure is operating properly.

**Figure 10.1**  
**Hydraulic Modeling Graph**  
**Option 4C**

### EDISTO BEACH PROPOSED RO PLANT OPTION 4C



- PMP-CW-1A - Option 4C (72 Hour) - 1,200 gpm RO, 3518 SF clearwell, 1,000 GPM FF at J-28 from 8-10 AM on Day 2 - Flow (Total)
- PMP-CW-1B - Option 4C (72 Hour) - 1,200 gpm RO, 3518 SF clearwell, 1,000 GPM FF at J-28 from 8-10 AM on Day 2 - Flow (Total)
- PMP-CW-2 - Option 4C (72 Hour) - 1,200 gpm RO, 3518 SF clearwell, 1,000 GPM FF at J-28 from 8-10 AM on Day 2 - Flow (Total)
- GST Booster Pump-2 - Option 4C (72 Hour) - 1,200 gpm RO, 3518 SF clearwell, 1,000 GPM FF at J-28 from 8-10 AM on Day 2 - Flow (Total)
- Elevated Tank - Option 4C (72 Hour) - 1,200 gpm RO, 3518 SF clearwell, 1,000 GPM FF at J-28 from 8-10 AM on Day 2 - Level (Calculated)
- T-CW-1 - Option 4C (72 Hour) - 1,200 gpm RO, 3518 SF clearwell, 1,000 GPM FF at J-28 from 8-10 AM on Day 2 - Level (Calculated)
- Ground Tank 1 - Option 4C (72 Hour) - 1,200 gpm RO, 3518 SF clearwell, 1,000 GPM FF at J-28 from 8-10 AM on Day 2 - Level (Calculated)

**FIGURE 10.1**



- Total well supply 1,521 gpm + 385 gpm Reserve
- Blended RO 1,728,000 gpd (1,200 gpm)
- High Service Pumps 1,200 gpm, 600 gpm, 600 gpm
- Clearwell Capacity 290,000 gallons
- Existing Storage ET=100,000 gal., GST=200,000 gal,

**Appendix A**

**Lab Analysis-Existing Well #6**

**TRIDENT LABS SERVICES, INC.**

ANALYTICAL LABORATORY

Soil, Water, Wastewater &amp; Industrial Chemical Analysis

9104 Canvas Lane Δ Ladson, South Carolina 29456

Telephone (843) 871-4999 Δ Fax (843) 875-2266

e-mail: tls@tridentlabs.com

**REPORT OF ANALYSIS**

Thomas &amp; Hutton Engineering

935 Houston Northcutt Blvd.

Mt. Pleasant, SC 29465

Attn: Mark Yodice

Report Date: 01/05/16

Sampled: 11/20/15 10:29

Collected By: JGL

Sample Matrix: DW

1 of 3

Received: 11/20/15 11:40

Received By: KDL

Sample Id: 0154218

Sample Number(s): 190427 - 190430

Project Name: Edisto Beach

Location: Well 6

ANALYSIS	METHOD	RESULT	UNITS	DATE/TIME	ANALYST
Sample Type: Grab					
Bicarbonate Alkalinity	SM 2320B	519	mg/l	11/23/15 10:00	LJH
Carbonate Alkalinity	SM 2320B	0	mg/l	11/23/15 10:00	LJH
Chloride	EPA 300.0	490	mg/l	11/20/15 15:33	MBL
Fluoride	EPA 300.0	2.56	mg/l	11/20/15 13:38	MBL
Nitrate-Nitrogen	EPA 300.0	< 0.5	mg/l	11/20/15 13:38	MBL
Residue, Filterable (TDS)	SM 2540C	1398	mg/l	11/25/15 12:00	ACE
Specific Conductance	EPA 120.1	2.61	mS/cm	11/20/15 14:00	ACE
Sulfate	EPA 300.0	52.8	mg/l	11/20/15 13:43	MBL
Metals Prep	EPA 200.2	Complete	None	11/24/15 08:00	MBL
Barium	EPA 200.7	< 0.050	mg/l	11/25/15 10:46	MBL
Calcium	EPA 200.7	5.3	mg/l	11/25/15 10:46	MBL
Chromium	EPA 200.7	0.005	mg/l	11/25/15 10:46	MBL
Copper	EPA 200.7	0.105	mg/l	11/25/15 10:46	MBL
Iron	EPA 200.7	< 0.3	mg/l	11/25/15 10:46	MBL
Manganese	EPA 200.7	< 0.010	mg/l	11/25/15 10:46	MBL
Zinc	EPA 200.7	0.089	mg/l	11/25/15 10:46	MBL
Aluminum	EPA 200.7	< 0.050	mg/l	11/25/15 10:46	MBL
Sub Work	Sub Contractor	Attached	None	12/04/15 14:16	JL

LABORATORY I.D. NO. 10122, FIELD SERVICES I.D. NO 08566

REPORT APPROVED BY:

Report Comments :

Amended Report: Incorrect Result entered.



**TRIDENT LABS SERVICES, INC.**

ANALYTICAL LABORATORY

Soil, Water, Wastewater &amp; Industrial Chemical Analysis

9104 Canvas Lane Δ Ladson, South Carolina 29456

Telephone (843) 871-4999 Δ Fax (843) 875-2266

e-mail: tls@tridentlabs.com

**QC SUMMARY**

Thomas & Hutton Engineering  
 935 Houston Northcutt Blvd.  
 Mt. Pleasant, SC 29465  
 Attn: Mark Yodice

Report Date: 1/5/16

Sample ID: 0154218

Batch	30113	Method : EPA 300.0					
Parameter		Expected	Actual Result	% Rec	Range	Analyst	Date/Time
LCS-CL Chloride		2	1.99	99.35	90 - 110	MBL	11/20/2015 1:42:34 PM
LCS-F Fluoride		2	2.16	108.15	90 - 110	MBL	11/20/2015 1:42:34 PM
LCS-NO3 Nitrate-Nitrogen		2	2.01	100.30	90 - 110	MBL	11/20/2015 1:42:34 PM
LCS-SO4 Sulfate		2	2.12	106.05	90 - 110	MBL	11/20/2015 1:42:34 PM
MSPK-F Fluoride		5	5.34	106.88	80 - 120	MBL	11/20/2015 1:42:34 PM
MSPK-NO3 Nitrate-Nitrogen		5	4.84	96.72	80 - 120	MBL	11/20/2015 1:42:34 PM
MSPK-CL Chloride		9.998	9.90	99.00	80 - 120	MBL	11/20/2015 1:42:34 PM
MSPK-SO4 Sulfate		20.2	20.50	101.49	80 - 120	MBL	11/20/2015 1:42:34 PM
Batch	30115	Method : EPA 120.1					
Parameter		Expected	Actual Result	% Rec	Range	Analyst	Date/Time
Duplicate		2.61	2.62	0.38	-10 - 10	MBL	11/20/2015 2:28:24 PM
LCS Specific Conductance		1410	1416.00	100.43	90 - 110	MBL	11/20/2015 2:28:24 PM
Batch	30125	Method : SM 2320B					
Parameter		Expected	Actual Result	% Rec	Range	Analyst	Date/Time
Duplicate Bicarbonate Alkalinity		0	0.00	0.00	-10 - 10	LJH	11/23/2015 11:40:19 AM
Batch	30126	Method : SM 2320B					
Parameter		Expected	Actual Result	% Rec	Range	Analyst	Date/Time
Duplicate Carbonate Alkalinity		0	0.00	0.00	-10 - 10	LJH	11/23/2015 11:43:42 AM
Batch	30150	Method : EPA 200.7					
Parameter		Expected	Actual Result	% Rec	Range	Analyst	Date/Time
LCS-AL Aluminum		1	1.09	109.00	85 - 115	MBL	11/25/2015 8:04:34 AM
LCS-BA Barium		1	1.09	109.00	85 - 115	MBL	11/25/2015 8:04:34 AM
LCS-CA Calcium		1	1.11	111.00	85 - 115	MBL	11/25/2015 8:04:34 AM
LCS-CR Chromium		1	1.06	106.00	85 - 115	MBL	11/25/2015 8:04:34 AM
LCS-CU Copper		1	1.02	102.00	85 - 115	MBL	11/25/2015 8:04:34 AM
LCS-FE Iron		1	1.24	124.00	85 - 115	MBL	11/25/2015 8:04:34 AM

LABORATORY I.D. NO. 10122, FIELD SERVICES I.D. NO 08566

REPORT APPROVED BY:

Report Comments :

Amended Report: Incorrect Result entered.

**TRIDENT LABS SERVICES, INC.**

ANALYTICAL LABORATORY

Soil, Water, Wastewater &amp; Industrial Chemical Analysis

9104 Canvas Lane Δ Ladson, South Carolina 29456  
Telephone (843) 871-4999 Δ Fax (843) 875-2266  
e-mail: [ts@tridentlabs.com](mailto:ts@tridentlabs.com)**QC SUMMARY**Thomas & Hutton Engineering  
935 Houston Northcutt Blvd.  
Mt. Pleasant, SC 29465  
Attn: Mark Yodice

Report Date: 1/5/16

Sample ID: 0154218

LCS-MN	Manganese	1	1.07	107.00	85 - 115	MBL	11/25/2015 8:04:34 AM
LCS-ZN	Zinc	1	1.07	107.00	85 - 115	MBL	11/25/2015 8:04:34 AM
MSPK-CR	Chromium	1	1.10	110.00	75 - 125	MBL	11/25/2015 8:04:34 AM
MSPK-CU	Copper	1	1.08	108.00	75 - 125	MBL	11/25/2015 8:04:34 AM
MSPK-MN	Manganese	1	1.09	109.00	75 - 125	MBL	11/25/2015 8:04:34 AM
MSPK-ZN	Zinc	1	1.23	123.00	75 - 125	MBL	11/25/2015 8:04:34 AM

Batch 30178

Method : SM 2540C

Parameter	Expected	Actual Result	% Rec	Range	Analyst	Date/Time
Duplicate Residue, Filterable (TDS)	1398	1490.00	6.58	-10 - 10	ACE	11/25/2015 12:00:00 PM

LABORATORY I.D. NO. 10122, FIELD SERVICES I.D. NO 08566

REPORT APPROVED BY:

Report Comments :

Ammended Report: Incorrect Result entered.

# Davis & Brown

PO Box 15038  
Quinby, SC 29506  
(843) 665-6746 FAX: (843) 629-1444

## Certificate of Analysis

Client: ACCESS ANALYTICAL  
7478 CARLISLE ST  
IRMO, SC 29063

South Carolina Certification Number: 21117

Contact: ASHLEY AMICK  
Client #: 941

Receipt Date: 02-Dec-15

Report Date: 07-Jan-16

Sample Date: 20-Nov-15

SDG #: SDG-109601

Lab Sample ID: LSID-242559

Sample ID: 190430

Approved By: Van Ward

Van Ward  
Lab Director

Parameter	Result	Reporting		Unit	Method	Flag	Date	Time	Analyst
		Limit							
Beryllium, Total	<0.001	0.001		mg/L	EPA 200.7		12/16/2015	11:40	JR
Boron, Total	2.01	0.02		mg/L	EPA 200.7		12/17/2015	14:53	JR
Magnesium, Total	8.07	0.02		mg/L	EPA 200.7		12/4/2015	19:50	JR
Nickel, Total	<0.005	0.005		mg/L	EPA 200.7		12/14/2015	13:28	JR
Potassium, Total	<25	25		mg/L	EPA 200.7		12/16/2015	9:07	JR
Sodium, Total	512	25		mg/L	EPA 200.7		12/16/2015	9:07	JR
Silver, Total	<0.005	0.005		mg/L	EPA 200.7 / 200.		12/15/2015	15:31	JR/AE
Mercury, Total	<0.20	0.2		ug/L	EPA 245.1		12/3/2015	9:00	CG
Thallium, Total	<0.5	0.5		ug/L	EPA 279.2/ 200.		12/16/2015	13:19	JR
Lead, Total	0.001	0.001		mg/L	SM 3113B-2010		1/5/2016	12:00	JR
Arsenic, Total	<0.005	0.005		mg/L	SM 3113B-99		1/5/2016	16:27	JR
Cadmium, Total-PQL	0.0001	0.0001		mg/L	SM 3113B-99		1/6/2016	10:21	JR
Selenium, Total	<0.005	0.005		mg/L	SM 3113B-99		1/6/2016	10:04	JR

Revision 2

**Appendix B**  
**Reverse Osmosis System Analysis**

Reverse Osmosis System Analysis for FILMTEC™ Membranes  
 Project: Santee Well 6 WQ Town Hall Cases  
 JEN, Harm R/O Systems, Inc.

ROSA 9.1 ConfigDB u399339\_356  
 Case: 5  
 9/25/2016

**Project Information:** Edisto Beach

**Case-specific:** three 320 gpm perm. skids

**System Details**

Feed Flow to Stage 1	426.67 gpm	Pass 1 Permeate Flow	320.01 gpm	Osmotic Pressure:	
Raw Water Flow to System	506.67 gpm	Pass 1 Recovery	75.00 %	Feed	16.50 psig
Feed Pressure	110.32 psig	Feed Temperature	25.0 C	Concentrate	62.46 psig
Flow Factor	0.85	Feed TDS	1724.21 mg/l	Average	39.48 psig
Chem. Dose (100% H2SO4)	0.00	Number of Elements	84	Average NDP	71.13 psig
Total Active Area	33600.00 ft²	Average Pass 1 Flux	13.71 gfd	Power	28.89 kW
Water Classification: Well Water SDI < 3		Bypass Blending Flow	80.00 gpm	Specific Energy	1.20 kWh/kgal
System Recovery	78.95 %	Total Blended Product	400.01 gpm		

Stage	Element	#PV	#Ele	Feed Flow (gpm)	Feed Press (psig)	Recirc Flow (gpm)	Conc Flow (gpm)	Conc Press (psig)	Perm Flow (gpm)	Avg Flux (gfd)	Perm Press (psig)	Boost Press (psig)	Perm TDS (mg/l)
1	BW30XFRLE-400/34	8	7	426.67	105.32	0.00	201.51	92.95	225.15	14.47	0.00	0.00	38.20
2	BW30XFRLE-400/34	4	7	201.51	117.95	0.00	106.65	106.18	94.86	12.20	0.00	30.00	107.06

Pass Streams (mg/l as Ion)									
Name	Feed	Adjusted Feed	Concentrate		Permeate				
			Stage 1	Stage 2	Stage 1	Stage 2	Total	Blended Total	
NH4+ + NH3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
K	18.08	18.08	37.69	69.92	0.52	1.46	0.80		4.25
Na	534.86	538.90	1128.03	2102.27	11.61	32.68	17.85		122.06
Mg	6.16	6.16	13.00	24.48	0.04	0.10	0.05		1.28
Ca	4.62	4.62	9.75	18.36	0.03	0.07	0.04		0.96
Sr	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00
Ba	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00
CO3	10.01	10.01	27.59	62.76	0.00	0.02	0.01		0.41
HCO3	586.49	586.49	1209.68	2221.57	17.19	47.75	26.25		141.52
NO3	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00
Cl	474.00	474.00	994.54	1858.57	8.11	23.08	12.55		104.84
F	3.30	3.30	6.87	12.72	0.10	0.29	0.16		0.79
SO4	55.15	55.15	116.35	218.89	0.38	1.07	0.58		11.50
SiO2	27.48	27.48	57.93	108.99	0.23	0.53	0.32		5.75
Boron	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00
CO2	4.28	4.28	8.02	14.79	5.06	9.11	6.26		4.71
TDS	1720.18	1724.21	3601.47	6698.55	38.20	107.06	58.61		393.35
pH	8.20	8.20	8.19	8.14	6.73	6.89	6.81		7.61

\*Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume any obligation or liability for results obtained or damages incurred from the application of this information. Because use conditions and applicable laws may differ from one location to another and may change with time, customer is responsible for determining whether products are appropriate for customer's use. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

Reverse Osmosis System Analysis for FILMTEC™ Membranes  
 Project: Santee Well 6 WQ Town Hall Cases  
 JEN, Harm R/O Systems, Inc.

ROSA 9.1 ConfigDB u399339\_356  
 Case: 5  
 9/25/2016

### Design Warnings

-None-

### Solubility Warnings

Langelier Saturation Index > 0

Stiff & Davis Stability Index > 0

CaF2 (% Saturation) > 100%

Antiscalants may be required. Consult your antiscalant manufacturer for dosing and maximum allowable system recovery.

### Stage Details

Stage 1 Element Recovery		Perm Flow (gpm)	Perm TDS (mg/l)	Feed Flow (gpm)	Feed TDS (mg/l)	Feed Press (psig)
1	0.09	4.73	21.84	53.33	1724.21	105.32
2	0.09	4.48	25.75	48.61	1889.39	102.76
3	0.10	4.24	30.55	44.13	2077.99	100.51
4	0.10	4.01	36.52	39.89	2294.93	98.53
5	0.11	3.79	44.07	35.88	2546.61	96.81
6	0.11	3.57	53.77	32.10	2841.03	95.32
7	0.12	3.34	66.51	28.53	3188.47	94.04
Stage 2 Element Recovery		Perm Flow (gpm)	Perm TDS (mg/l)	Feed Flow (gpm)	Feed TDS (mg/l)	Feed Press (psig)
1	0.09	4.53	57.00	50.38	3601.47	117.95
2	0.09	4.17	69.29	45.85	3951.00	115.58
3	0.09	3.79	85.11	41.68	4338.14	113.49
4	0.09	3.40	105.64	37.89	4762.32	111.65
5	0.09	3.00	132.48	34.49	5219.96	110.03
6	0.08	2.60	167.77	31.49	5703.56	108.59
7	0.08	2.22	214.23	28.88	6201.44	107.32

Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume any obligation or liability for results obtained or damages incurred from the application of this information. Because use conditions and applicable laws may differ from one location to another and may change with time, customer is responsible for determining whether products are appropriate for customer's use. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

**Scaling Calculations**

	Raw Water	Adjusted Feed	Concentrate
pH	8.20	8.20	8.14
Langelier Saturation Index	0.00	0.00	1.08
Stiff & Davis Stability Index	0.29	0.29	0.85
Ionic Strength (Molal)	0.03	0.03	0.10
TDS (mg/l)	1720.18	1724.21	6698.55
HCO <sub>3</sub>	586.49	586.49	2221.57
CO <sub>2</sub>	4.28	4.28	14.79
CO <sub>3</sub>	10.01	10.01	62.76
CaSO <sub>4</sub> (% Saturation)	0.05	0.05	0.35
BaSO <sub>4</sub> (% Saturation)	0.00	0.00	0.00
SrSO <sub>4</sub> (% Saturation)	0.00	0.00	0.00
CaF <sub>2</sub> (% Saturation)	6.69	6.69	395.23
SiO <sub>2</sub> (% Saturation)	17.82	17.82	73.45
Mg(OH) <sub>2</sub> (% Saturation)	0.01	0.01	0.02

To balance: 4.03 mg/l Na added to feed.