

**DOCUMENT 00901  
ADDENDUM No. 1**

**JUN 20 2022**

**PART 1 GENERAL**

1. **This Addendum applies to the following project: Upgrades to Pump Station "B". Please add Document 00901 – Addendum No. 1 to the Contract Documents & Specifications for this project.**
2. **Revise Document 00003 – Table Of Contents of the Contract Documents & Specifications to include the following:**
  - i. Document 00901 – Addendum No. 1.

**PART 2 SPECIFICATIONS**

1. **Section 11306 – Submersible Pumps – Part 2.1.B.1. shall be modified to read as follows:**
  1. ABS Pumps and KSB Pumps.
2. **Section 11306 – Submersible Pumps – Part 2.2.A shall be modified to read as follows:**
  - A. Furnish two (2) submersible non-clog wastewater pumps. Each.....
3. **Section 11400 – Control Panels and Systems – Part 2.4.F.8.h. shall be modified to read as follows:**
  - h. Programmable controllers shall be Square D – Modicon Quantum or Square D – Modicon Momentum or Allen Bradley Micro-Logics.

**PART 3 DRAWINGS**

1. None

**PART 4 CLARIFICATIONS**

1. None

**END OF DOCUMENT**