

ADDENDUM #1

Question: Should the fittings match existing fittings?

Answer: Yes, all fittings should match as well as the thickness of cable should match. The existing fittings are a crimp deck turn buckle style with a crimp anchor fitting. When replacing, repairing or extending the stainless-steel cable, the same fittings and thickness of cable should be quoted and used.

Question: Do you want stainless-steel cable stiffeners installed on the vacant sections where the extension will be installed?

Answer: Yes, stainless-steel cable stiffeners should be installed in the center of each section just like the existing cable sections have.