

Addendum # 2 – Questions

9/21/21

RFP 2021-09

Question 1: The ATS specifications call for the unit to be NEMA 4X. If we put the unit inside of the ATS Cabinet on-site, would NEMA 3R be acceptable? **Yes**

Question 2: Are we only responsible for the electrical requirements highlighted in green on the drawing or are there other requirements (lights, etc.)? **Need additional information/clarification on the question.**

Question 3: Will you accept Gillette Generators for this job? Submittal Package and Case Study attached. **No**

Question 4: The ATS spec also calls for an ASCO 7000 switch (or equivalent) with the isolation Bi-pass option. We rarely see the features of the ASCO 7000 switch or the Bi-Pass option required for well pump ATS applications. Both of these options significantly increase your price as well as your lead time. Please let us know if the ASCO Series 300 switch (or equivalent) without the Bi-Pass option will be acceptable. **Yes, ASCO 300 series or equivalent are acceptable.**

Please review Addendum # 3 regarding RFP amendments.