

Question: What type(s) of site work is expected?

Answer: The site must be cleared and leveled before construction may begin. All walkways, paths, and entryways must meet the 2017 ICC A 117.1-Assessible and Usable Buildings and Facilities (Assessible Code).